



CONSTRUCTION NOTES:

- ① BANDED RUBBER COUPLING WITH OUTSIDE TYPE 316 STAINLESS STEEL SHEAR RING
- ② WYE FITTING

NOTES:

1. When 12" minimum space between edge of coupling and bell cannot be provided, cut-out nearest bell joint and insert plain-end pipe.
2. All debris shall be kept out of the sewer. The pipe reach cut-into shall be cleaned as directed by the District Representative.
3. Damaged pipe shall be replaced as directed by the District Representative.
4. Saddle-type connections shall only be used for special situations, and shall not be constructed without prior District approval.
5. 8" and larger diameter laterals shall be connected to mainline via manhole only, per EVWD Std. Dwg. S-104.

CUT-IN WYE CONNECTION

M:\Engineering - Secured\Standards\DWG\2022 Update\Sewer



EAST VALLEY WATER DISTRICT, ENGINEERING DEPARTMENT
 APPROVED BY:

Jeff Noelte

 JEFF NOELTE, P.E. 67924
 DIRECTOR of ENGINEERING and OPERATIONS

APRIL 2022
 REVISION

EVWD
 STD. DWG.
 S-110
 SHEET 1 OF 1